CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: T- 4358

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2017-05-15-08** **Date: 17-05-17**

Customer : Assistant Executive Engineer, Shettyhalli Sub Division, BBMP, Bangalore.

Address : Shettyhalli Sub Division, BBMP, Bangalore.

Project Name : Improvements to RCC drains and CC roads at Mallasandra in Ward No.13 Mallasandra Shettyhalli Sub Division.

Agency : Technical Manager(West), Karnataka Rural Infrastructure Development Limited, Project Implementation unit, No/280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-

Customer's Reference : BBMP/EE/DD/WO/55/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 15-05-17

Sample ID No : 2017-05-15-08-01

Customer ID : PCC

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 17/05/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	PCC	M20	10/05/2017	17/05/2017	150.15 X 150.47 X 150.98	22593	8.174	399.9	17.7	17.1
2	PCC	M20	10/05/2017	17/05/2017	150.44 X 150.78 X 150.77	22683	8.174	374.3	16.5	
3	PCC	M20	10/05/2017	17/05/2017	150.64 X 150.88 X 150.75	22729	8.125	390.9	17.2	

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harsitha

AE-13
ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಎಸ್.ಎಂ. ರಸ್ತೆ, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

FOR CIVIL Pro.
CIVIL Pro Sig..... Date..... BANGALORE
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2017-05-15-08** **Date: 07-06-17**

Customer : Assistant Executive Engineer, Shettyhalli Sub Division, BBMP, Bangalore.

Address : Shettyhalli Sub Division, BBMP, Bangalore.

Project Name : Improvements to RCC drains and CC roads at Mallasandra in Ward No.13 Mallasandra Shettyhalli Sub Division.

Agency : Technical Manager(West), Karnataka Rural Infrastructure Development Limited, Project Implementation unit, No/280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-

Customer's Reference : BBMP/EE/DD/WO/55/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 15-05-17

Sample ID No : 2017-05-15-08-02

Customer ID : PCC

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 07/06/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	PCC	M20	10/05/2017	07/06/2017	150.88 X 150.64 X 150.88	22729	8.174	534.1	23.5	23.3
2	PCC	M20	10/05/2017	07/06/2017	150.47 X 150.66 X 150.64	22670	8.155	519.1	22.9	
3	PCC	M20	10/05/2017	07/06/2017	149.78 X 150.61 X 150.65	22558	8.179	530.1	23.5	

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harsitha

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

AE - 13

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಎಸ್.ಎಂ. ರಸ್ತೆ, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2017-05-19-06** **Date: 22-05-17**

Customer : Assistant Executive Engineer, Shettyhalli Sub Division, BBMP, Bangalore.

Address : Shettyhalli Sub Division, BBMP, Bangalore.

Project Name : Improvements to RCC drains and CC roads at Mallasandra in Ward No.13 Mallasandra Shettyhalli Sub Division.

Agency : Technical Manager(West), Karnataka Rural Infrastructure Development Limited, Project Implementation unit, No/280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-560 010

Customer's Reference : BBMP/EE/DD/WO/55/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 19-05-17

Sample ID No : 2017-05-19-06-01

Customer ID : Drain Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M30 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 22/05/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M30	15/05/2017	22/05/2017	150.54 X 150.43 X 150.66	22646	8.165	575.2	25.4	25.4
2	Drain Concrete	M30	15/05/2017	22/05/2017	149.65 X 150.11 X 150.65	22464	8.153	586.3	26.1	
3	Drain Concrete	M30	15/05/2017	22/05/2017	149.65 X 150.65 X 150.54	22545	8.165	559.1	24.8	

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harsitha

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

AE -13

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : CP-2017-05-19-06 **Date: 12-06-17**

Customer : Assistant Executive Engineer, Shettyhalli Sub Division, BBMP, Bangalore.

Address : Shettyhalli Sub Division, BBMP, Bangalore.

Project Name : Improvements to RCC drains and CC roads at Mallasandra in Ward No.13 Mallasandra Shettyhalli Sub Division.

Agency : Technical Manager(West), Karnataka Rural Infrastructure Development Limited, Project Implementation unit, No/280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-560 010

Customer's Reference : BBMP/EE/DD/WO/55/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 19-05-17

Sample ID No : 2017-05-19-06-02

Customer ID : Drain Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M30 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 12/06/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M30	15/05/2017	12/06/2017	151.02 X 150.71 X 150.87	22760	8.154	762.5	33.5	32.9
2	Drain Concrete	M30	15/05/2017	12/06/2017	150.43 X 149.13 X 150.43	22434	8.143	735.8	32.8	
3	Drain Concrete	M30	15/05/2017	12/06/2017	150.65 X 150.19 X 149.86	22626	8.075	733.1	32.4	

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harsitha

AE-13
ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಎಸ್.ಎಂ. ರಸ್ತೆ, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

FOR CIVIL Pro.
CIVIL Pro Sig..... Date..... BANGALORE
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: T- 4358

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2017-05-19-06** **Date: 23-05-17**

Customer : Assistant Executive Engineer, Shettyhalli Sub Division, BBMP, Bangalore.

Address : Shettyhalli Sub Division, BBMP, Bangalore.

Project Name : Improvements to RCC drains and CC roads at Mallasandra in Ward No.13 Mallasandra Shettyhalli Sub Division.

Agency : Technical Manager(West), Karnataka Rural Infrastructure Development Limited, Project Implementation unit, No/280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-560 010

Customer's Reference : BBMP/EE/DD/WO/55/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 19-05-17

Sample ID No : 2017-05-19-06-03

Customer ID : Drain Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M30 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 23/05/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M30	16/05/2017	23/05/2017	149.88 X 150.54 X 150.32	22563	8.165	559.6	24.8	25.5
2	Drain Concrete	M30	16/05/2017	23/05/2017	149.87 X 150.26 X 150.44	22519	8.115	587.8	26.1	
3	Drain Concrete	M30	16/05/2017	23/05/2017	150.75 X 150.55 X 149.98	22695	8.148	578.7	25.5	

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harsitha

AE -13

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಎಸ್.ಎಂ. ರಸ್ತೆ, ರಾಜಾಜಿನಗರ, ಬೆಂಗಳೂರು

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: T- 4358

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : CP-2017-05-19-06 **Date: 13-06-17**

Customer : Assistant Executive Engineer, Shettyhalli Sub Division, BBMP, Bangalore.

Address : Shettyhalli Sub Division, BBMP, Bangalore.

Project Name : Improvements to RCC drains and CC roads at Mallasandra in Ward No.13 Mallasandra Shettyhalli Sub Division.

Agency : Technical Manager(West), Karnataka Rural Infrastructure Development Limited, Project Implementation unit, No/280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-560 010

Customer's Reference : BBMP/EE/DD/WO/55/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 19-05-17

Sample ID No : 2017-05-19-06-04

Customer ID : Drain Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M30 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 13/06/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen	Cross sectional area	Weight of the sample	Failure Load	Compressive strength	Average Compressive Strength
					(mm)	(Sq.mm)	(kg)	(KN)	(N/mm^2)	(N/mm^2)
1	Drain Concrete	M30	16/05/2017	13/06/2017	150.87 X 149.98 X 150.23	22627	8.165	742.2	32.8	32.9
2	Drain Concrete	M30	16/05/2017	13/06/2017	150.76 X 150.55 X 150.43	22697	8.154	735.4	32.4	
3	Drain Concrete	M30	16/05/2017	13/06/2017	150.53 X 150.18 X 150.43	22607	8.145	755.1	33.4	

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harsitha

AE-13
ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಎಸ್.ಎಂ. ರಸ್ತೆ, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2017-05-19-06** **Date: 24-05-17**

Customer : Assistant Executive Engineer, Shettyhalli Sub Division, BBMP, Bangalore.

Address : Shettyhalli Sub Division, BBMP, Bangalore.

Project Name : Improvements to RCC drains and CC roads at Mallasandra in Ward No.13 Mallasandra Shettyhalli Sub Division.

Agency : Technical Manager(West), Karnataka Rural Infrastructure Development Limited, Project Implementation unit, No.280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-560 010

Customer's Reference : BBMP/EE/DD/WO/55/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 19-05-17

Sample ID No : 2017-05-19-06-05

Customer ID : Drain Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M30 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 24/05/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen	Cross sectional area	Weight of the sample	Failure Load	Compressive strength	Average Compressive Strength
					(mm)	(Sq.mm)	(kg)	(KN)	(N/mm^2)	(N/mm^2)
1	Drain Concrete	M30	17/05/2017	24/05/2017	151.06 X 149.98 X 150.65	22656	8.115	561.9	24.8	24.7
2	Drain Concrete	M30	17/05/2017	24/05/2017	150.65 X 150.88 X 150.76	22730	8.097	550.1	24.2	
3	Drain Concrete	M30	17/05/2017	24/05/2017	150.33 X 150.87 X 150.76	22680	8.165	569.3	25.1	

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harsitha

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

A6-13

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Page 1/1
****End of Report****

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2017-05-19-06** **Date: 14-06-17**

Customer : Assistant Executive Engineer, Shettyhalli Sub Division, BBMP, Bangalore.

Address : Shettyhalli Sub Division, BBMP, Bangalore.

Project Name : Improvements to RCC drains and CC roads at Mallasandra in Ward No.13 Mallasandra Shettyhalli Sub Division.

Agency : Technical Manager(West), Karnataka Rural Infrastructure Development Limited, Project Implementation unit, No.280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-560 010

Customer's Reference : BBMP/EE/DD/WO/55/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 19-05-17

Sample ID No : 2017-05-19-06-06

Customer ID : Drain Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M30 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 14/06/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M30	17/05/2017	14/06/2017	149.11 X 150.81 X 149.09	22487	8.165	753.3	33.5	33.3
2	Drain Concrete	M30	17/05/2017	14/06/2017	151.99 X 150.65 X 149.22	22897	8.116	748.7	32.7	
3	Drain Concrete	M30	17/05/2017	14/06/2017	150.76 X 151.22 X 150.26	22798	8.175	768.3	33.7	

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harsitha

FOR CIVIL Pro.
CIVIL Pro Sig..... Date..... BANGALORE
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಎಸ್.ಎಂ. ರಸ್ತೆ, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com